

## Office of the Chief Engineer (Electrical),

Public Works Department, 3Rd Floor, Bandhkam Bhavan, 25, Marzban Road, Fort, Mumbai-400 001.



Email: elmumbai.ce@mahapwd.com Tel. No.: 022 - 22013415/16/17 Website: www.mahapwd.com Fax No.: 022 - 22016900 No. CE(E) / Desk-3(5) / (c() / Year 2018.

To,

M/s U - Protec Earthling Pvt.Ltd. Sr.No.168, Office No.1, Dhanashree Apartment, Kasba Peth, Pune - 411011

Subject

Approval to use material on work carried out by Government of Maharashtra

Reference

- M/s U -Protec Earthing Pvt Ltd. यांचे पत्र क्रमांक पिरंक दिनांक १७.३.२०१८
- या कार्यालयाचे पत्र क्रमांक मुअ(वि)/का-३(५)/८७२/२०१७ दिनांक ३१.३.२०१७ 7)
- 3) M/s U -Protec Earthing Pvt Ltd. यांचे पत्र क्र निरंक दिनांक १२.४.२०१७
- या कार्यालयाचे पत्र क्रमांक मुअ(वि)/का-३(५)/१३५४/२०१७ दिनांक १९.५.२०१७
- M/s U -Protec Earthing Pvt Ltd. यांचे पत्र क्र निरंक दिनांक १०.४.२०१८ 4)
- कार्यालयाचे पत्र क्रमांक मुअ(वि)/का-३(५)/१११५/२०१७ दिनांक १२.५.२०१८ **E**)
- कार्यकारी अभियंता, पुणे विद्युत विभाग, पुणे यांचे पत्र क्रमांक काअ/उ.अ.(स्वी.स)/७०४३/२०१८ दिनांक १३.११.२०१८

Sir,

The subject proposal submitted by you was examined by this office and now the undersigned is please to accord approval to the following materials for using it on works carried out by Government of Maharashtra w.e.f. the date of issue of this letter.

Name of Material

Place of Manufacture

"Earthing Electrode"

Shop No.1, 166/167/168, Kasba Peth, Pune - 411011

**Brand Name** 

Technical Specifications of the materials

U - PROTEC EARTHING

Name of Product Vailidity Electrode of 17.2mm diameter low carbon steel Unto with 250 micron molecular copper bonded earthing 31th October, 2021 rod. length: 3 mtrs.

The above approval is given subject to:-

The performance of the material during this period remains satisfactory.

The product should be of the same quality, design and shape as the specimen tested.

Any changes in design, specifications and contents of the material should be brought to the notice of this office and get approved.

The department reserves the right to withdraw the approval at any time without assigning any reason.

Yours faithfully,

(S. A. PATIL) Chief Engineer (Electrical), P. W. D., Mumbai.

<sup>\*</sup>Copy forwarded to Superintending Engineer, Regional Electrical Circle, P.W.D., Pune / Nagpur for information.

<sup>\*</sup>Copy forwarded to Executive Engineer, P. W. Electrical Division, South Mumbai/Central Mumbai/North Mumbai/ Agriculture Construction-5/Thane/Pune/Kolhapur/Nashik/Aurangabad/Osmanabad/Amaravati/Nagpur for information.